

5. (a) What is the significance of Incremental Cost (λ) ?

(b) Derive expression for representation of transmission loss by B-coefficients. $7\frac{1}{2}, 7\frac{1}{2}$

Section-C

15 each

6. What are the different methods for Voltage Control ? Explain them in brief.

7. Explain with block diagram of two area load frequency control.

Section-D

8. (a) Draw power angle curve and also derive an expression for this.

(b) Define Transient Stability. Discuss various assumptions made during analysis of the system. $7\frac{1}{2}, 7\frac{1}{2}$

9. What do you understand by equal area criteria and plot a δ Vs. t curve for the stable and unstable system ? 15

3349_1100

(4)

RD-3331

Roll No. :

Total No. of Questions : 9]

[Total No. of Pages : 4

3349

B.Tech. (EE) 6th Semester (Supplementary)

Examination, July-2021

(G Scheme)

POWER SYSTEM-II

Paper-PCC-EE-302-G

Time : Three Hours]

[Maximum Marks : 75

Before answering the questions, candidates should ensure that they have been supplied the correct and complete question paper. No complaint in this regard, will be entertained after examination.

Note :- Attempt five questions in all. Question No. 1 is compulsory. Attempt four more questions from the Sections-A, B, C and D by selecting one question from each Section.

1. (a) What do you mean by control area in Power System ? Explain it.

(b) What are the advantages and disadvantages of GS method ?

3349_1100

(1)

RD-3331

P.T.O.

- (c) Define the term ITL.
- (d) What is the significance of Incremental Cost (λ) ?
- (e) In which condition generator bus is treated as load bus ?
- (f) What is the objective of the economic dispatch problem ? $2\frac{1}{2} \times 6 = 15$

Section-A

15 each

2. Detail the algorithm to perform load flow using NR method and also draw its flowchart.
3. The load flow data for the sample power system are given below. The voltage magnitude at bus 2 is to be maintained at 1.04 p.u. the max and min reactive power limits of the generator at bus 2 are 0.35 and 0.0 p.u. respectively. Determine the set of load flow equation at the end of first iteration by using G-S method :

Bus Code	Impedance	Line charging Admittance
1-2	$0.08 + j 0.24$	0
1-3	$0.02 + j 0.06$	0
2-3	$0.06 + j 0.18$	0

3349_1100

(2)

RD-3331

Schedule of generation of loads :

Bus Code	Assumed Voltage	Generation		Load	
		MW	MVAR	MW	MVAR
1	$1.06 + j 0.0$	0	0	0	0
2	$1.00 + j 0.0$	0.2	0	0	0
3	$1.00 + j 0.0$	0	0	0.6	0.25

Section-B

4. Incremental fuel cost in rupees per MWh for a plant consisting of two units are :

$$dC_1/dP_{G1} = 0.20 P_{G1} + 40$$

$$dC_2/dP_{G2} = 0.40 P_{G2} + 30$$

and the generator limits are as follows :

$$30 \text{ MW} \leq P_{G1} \leq 175 \text{ MW}$$

$$20 \text{ MW} \leq P_{G2} \leq 125 \text{ MW}$$

Assume that both units are operating at all times. How will the load be shared between the two units as the system load varies over the full range of the load values ? What are the corresponding value of the plant incremental costs ?

15

3349_1100

(3)

RD-3331

P.T.O.